POWER GRID CORPORATION OF INDIA LIMITED

(A Government of India Enterprise)

दिनांक: 26-SEP-2022

निर्माता अनुमोदन / MANUFACTURER APPROVAL

संदर्भ: : CC/QA&I/2022/Letter/E-539619/323

प्रस्तावकर्ता का नाम/ Name of Proposer	Transrail Lighting Limited and Sterlite Power Transmission Limited			
निर्माता का नाम/ Name of Manufacturer	Usha Martin Limited			
सी.आई.एन संख्या/ CIN Number	L31400WB1986PLC091621			
निर्माता का पता/	Wire & Wire Rope Unit, Tatisilwai			
Address of Manufacturer	City: Ranchi	State	/Country: Jharkhand/India	Pin/Zip Code: 835103
निर्माता कोड/ Manufacturer Code	3000000120			
नाम और संपर्क विवरण/	Shri Brajlal Sarkar			
Name & Contact details	+91- 9304112612		BRAG@USHAMARTIN.CO.IN	
मद का नाम/ Item Name	Galvanized Core Wire of Ultra High Strength and Mega Strength			
वैधता अवधि/ Validity period up to	25-SEP-2023			

Background details: This has reference to respective e-mails from M/s Transrail and M/s Sterlite dated 06.08.2022 and 17.08.2022 regarding manufacturer approval of M/s Usha Martin for supply of Galvanized Core Wire of Ultra High Strength and Mega Strength. Based on the request and submission of relevant documents, assessment was carried out by our representative at above mentioned works on 09.09.2022 and 10.09.2022. On successful compliance of observation points made during assessment we hereby convey our acceptance of **M/s Usha Martin Limited**, having works address as above, for supply of aforementioned items.

Please note that further approval shall be considered based upon performance, quality and supplies made during this approval period. It is to be ensured that request for renewal of above approval shall be forwarded at least one month before expiry of this approval.

Contractor and Manufacturer shall be fully responsible for satisfactory performance of approved products. Please note that the items supplied shall meet the requirements of POWERGRID Specifications/ Approved Drawing/ Data Sheets/ GTP/MQP, relevant IS standards. Manufacturer shall ensure that the above documents are available at the works so that proper inspection is carried out without delay. If, at any point of time, any abnormality is noticed in this regard, we reserve the right to increase our involvement by way of additional inspection and/or additional customer inspection points (CIP) at any stage or withdraw this approval with immediate effect.

Special Remarks:

Following points are also to be ensured by M/s Usha Martin:

- 1. As committed by M/s Usha Martin, suitable tensile testing machine with extensometer with provision for testing samples for "Elongation at break" shall be installed by them by January'2023. Till then samples for "Elongation at break" shall be tested at third party laboratory or Conductor manufacturer's testing facilities.
- 2. As an improvement point and agreed by M/s Usha Martin, sensor based digital display shall be installed near Galvanizing area for temperature monitoring of Zinc bath by November'2022.
- 3. Suitable action to be taken regarding inclusion of Galvanizing process in the upcoming revision of pollution clearance certificate pertaining to M/s Usha Martin.

Note 1: "The ministry of MSME has launched the "Financial Support to MSMEs in ZED certification scheme" for benefit of MSMEs. MSMEs are requested to avail maximum benefits under the scheme. For more details on ZED, you may please visit this link-(https://zed.org.in/)."

Note 2: Letter regarding- Non-Indulgence in Fraudulent / Unethical Practices attached.

संजीव कुमार पांडेय महाप्रबंधक (गु॰ आ॰ एवं नि॰))

प्रति:

- 1) सम्बंधित निरीक्षण कार्यालय
- 2) M/s Transrail, Silvassa
- 3) M/s Sterlite, Silvassa

Enclosure: As above

Website: www.powergridindia.com